IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Tensley Rucker DATE 4-6-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1142 King St off murdock Rd.


S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other Repair

No. Bedrooms _____ No. Bathrooms _____
Garbage Disposal Unit Yes ( ) No ( )
Auto. Dishwasher Yes ( ) No ( )
Auto. Wash. Machine Yes ( ) No ( )
Site Suitable Yes ( ) No ( )
Lot Area _____

Character & Porosity of Soil Cecil Clay
Percolation Rate _____
Topography 2 to 6%
Depth to Water Table 10'+
Rock or other impervious formations none



Plot of System

Size of Tank Existing Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 675 Linear Ft. 225
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by William Culbertson

IMPROVEMENTS PERMIT BY Andrew Causey

COMMENTS: _____

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 4-6-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold