IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Reich Reality DATE 9-8-78 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION Murtock Rd TL on King St. 500' on right
1133 King St. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	cecil clay
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	60 min/inch
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	4% slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+
Lot Area 1/2 acre			Rock or other impervious formations	none



Plot of System

Size of Tank EXISTING Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Sam Oswalt

IMPROVEMENTS PERMIT BY R. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY R. C. Moore DATE 9-8-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold