CITY OF STATESVILLE.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR C+C CUSTOM HOMES DATE 8-4-89 PERMIT NO. D 11.

PHONE: Business _____ Home _____

LOCATION 747 Ronda Drive S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 100' X 150'

Character & Porosity of Soil Brown Suitable.
Percolation Rate Test by Pit.
Topography Level Lot
Depth to Water Table none observed.
Rock or other impervious formations none observed.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 400 Linear Ft. 300
Depth of Stone in Lines 24"

Water Supply: Individual (✓)
Public ( )

Installed by Paul Kenney Frye

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

Plot of System

IMPROVEMENTS PERMIT BY J. C. Howe

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 8-4-89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold