IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Clemhouse Bldg. Co. DATE 11/18/79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION E. Broad St., T.R. on Terra Drive, S Sharon Dr.

S. R. No. _____


SUBDIVISION NAME Dal Wan Section IV LOT NO. 140 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____ Prov. Suitable

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	CCL3
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	slower - mod
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	6-10%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	wk
			Rock or other impervious formations	none observed

Lot Area 100 X 150



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 990 Linear Ft. 330
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public ( )

Installed by Wm Sutton

IMPROVEMENTS PERMIT BY Glenn Fox, Jr.

COMMENTS: Jack Moore area

CERTIFICATE OF COMPLETION BY Andrew E. Carey DATE 11/18/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold