IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Icenhour Bldg Co. DATE 8-29-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION East Broad St. TR on Toria Drive Cross Creek TL 200' on R S. R. No. _____


SUBDIVISION NAME Oal Wan LOT NO. 142 SECTION OR BLOCK NO. IV

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 1/2 acre

Character & Porosity of Soil C & C2
Percolation Rate 100 min/inch
Topography 4-70 slope
Depth to Water Table 10'+
Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by Wes Litton

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: Landscape & Pipe Gutters so that surface water will not stand over Tank or lines.

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 8-22-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold