IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Rickey Hobbs DATE 3-12-84 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION East Broad TR on Toria at end TL 1 block TR on Randa Drive 1/8 mi on L.

SUBDIVISION NAME Dalwan LOT NO. 114 SECTION OR BLOCK NO. IV S. R. No. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	1" 4 gal/55' / 1" 5 gal
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 to 6%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+
Lot Area 15,000 sq'+			Rock or other impervious formations	none



Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Robert Hoke

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY R. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY R. C. Moore

EXISTING SYSTEM CHECKED BY: _____ DATE 3-12-84

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold