IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Icenhour Bldg Co. DATE 10-31-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Dal Wan Heights IV S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 103 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2 1/2

Garbage Disposal Unit	Yes	✓	No	( )
Auto. Dishwasher	Yes	✓	No	( )
Auto. Wash. Machine	Yes	✓	No	( )
Site Suitable	Yes	✓	No	( )

Lot Area 1/2 acre

Character & Porosity of Soil CF Oz + Parent material
Percolation Rate <45 / [redacted] inch
Topography 6% slope
Depth to Water Table 10'+
Rock or other impervious formations none



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public ✓

Installed by Eddie Yountz

IMPROVEMENTS PERMIT BY Glenn Fox Jr. amended 10-30-78 by J.C. Moore

COMMENTS: * reason - less space than originally thought that was available to use. Due to location of Telephone

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 10-31-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold