IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Richard Boyd DATE 3-5-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION East Bend Rt. 76 in Bell Terre Last House on Rt. _____ S. R. No. _____


SUBDIVISION NAME Bell Terre LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Sandy	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	Very Fast	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slopes back	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	4ft	
			Rock or other impervious formations	None	

Lot Area 264 x 175



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Herbie Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS: You should be landscaped to have ample cover Nitrification field

CERTIFICATE OF COMPLETION BY Glenn Ford Jr. DATE 3/5/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold