IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Larry murdock DATE 5-9-83 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 2613 East Greenbrair Rd

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other Repair

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )	Character & Porosity of Soil	Clay
Auto. Dishwasher	Yes ( )	No ( )	Percolation Rate	.3 gal/ft²/day
Auto. Wash. Machine	Yes ( )	No ( )	Topography	2 to 20 %
Site Suitable	Yes ( )	No ( )	Depth to Water Table	10'+
			Rock or other impervious formations	None

Lot Area _____

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank Existing Gals.

Nitrification Field:

No. of Lines 1

Sq. Ft. 180 Linear Ft. 60

Depth of Stone in Lines 16"

Water Supply: Individual ( )

Public (✓)

16 TON Pit at end of line

Installed by Roger Sigmon

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY L. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 5-7-83

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold