IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Coleman Absher DATE 5-12-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 2710 Murdock Rd

S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other Repair

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Cecil Clay
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	60 min/inch
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-7%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+
			Rock or other impervious formations	none

Lot Area 15,000 sq'



Plot of System

Size of Tank Existing Gals.
Nitrification Field:
No. of Lines 16 Ton Pit
Sq. Ft. _____ Linear Ft. _____
Depth of Stone in Lines _____
Water Supply: Individual ( )
Public (✓)

Installed by Harlee Lackey

IMPROVEMENTS PERMIT BY R. C. Moore

COMMENTS: Septic Tank needs pumping has large amount of sludge + grease on top of water.

CERTIFICATE OF COMPLETION BY R. C. Moore DATE 5-12-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold