ON-SITE WASTEWATER SECTION COUNTY:

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Chris Davidson OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED:
PROPOSED FACILITY:
PROPERTY SIZE: 3.75 acres
LOCATION OF SITE:
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	linear 15%	0 to 4"	L	GR		.1942 WETNES CONDITION - N/A
		4 to 36	C	ABK	1:1	.1943/.1956 SAPROLITE - N/A
		36 to 48	Transition			.1944 RESTRICTIVE HORIZON - N/A
						.1945 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3
2	linear 15%	0 to 4	L	GR		.1942 WETNES CONDITION - N/A
		4 to 36	C	ABK	1:1	.1943/.1956 SAPROLITE - N/A
		36 to 48	Transition			.1944 RESTRICTIVE HORIZON - N/A
						.1945 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3
3	linear 5 to 20%	0 to 4"	L	GR		.1942 WETNESS CONDITION - chroma 2 mottling 30 to 36"
		4 to 36"	C	ABK	mixed	.1943/.1956 SAPROLITE - N/A
		36"	C	ABK	2:1	.1944 RESTRICTIVE HORIZON - U
						.1945 PROFILE CLASSIFICATION - U
						PROFILE LTAR - <.1
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1945 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1945 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) yes SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .3
OTHER FACTORS(.1946) SYSTEM TYPE: Conv. Gravity
EVALUATED BY: J-C-moore OTHER(S) PRESENT: Neil Hall Sonny Torrence Chris Davidson
COMMENTS:

DRAF