IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR K & H Const. Co. DATE 7-26-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION East Broad St Lot S/W corner of Montgomery Dr. _____ S. R. No. _____


SUBDIVISION NAME Mitchell Village Section #1 LOT NO. 9 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Sandy Clay	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	5 min	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slopes to back	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	none	
			Rock or other impervious formations	none	

Lot Area 20,000



Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 648 Linear Ft. 243
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by Hale Septic Tank Co.

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Todd Jr. DATE 7/26/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold