IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Harry Turner DATE 6-11-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION East Broad St. Ext. Right on Green Brier Rd Cross Creek 2nd house on Rt. S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 20,800

Character & Porosity of Soil Red Clay
Percolation Rate _____
Topography Slopeto Creek
Depth to Water Table _____
Rock or other impervious formations Some Rock in center of Drainfield



Murdock. Plot System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 56 2½ Linear Ft. 225
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Lackey Bros.

IMPROVEMENTS PERMIT BY _____

COMMENTS: Layout made prior to new Regulations.

CERTIFICATE OF COMPLETION BY Glenn M.R. DATE 6-11-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold