IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jewell Whiteside DATE 7-3-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 2860 Murdock Road S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area _____


Character & Porosity of Soil C L B2

Percolation Rate 2

Topography L To Slope

Depth to Water Table 10'+

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 600 Linear Ft. 200

Depth of Stone in Lines 16"

Water Supply: Individual (✓)
Public ( )

Installed by Don Lackey

IMPROVEMENTS PERMIT BY Glenn Fox

COMMENTS: _____

CERTIFICATE OF COMPLETION BY A. C. Moore DATE 7-3-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold