IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Boar Bldg. Co DATE 12/28/79 PERMIT NO.

PHONE: Business Home

LOCATION E. Broad St., T.K. on Montgomery, T.K on Flowes Circle, 1/4 mile on left S. R. No.

SUBDIVISION NAME Mitchelaire LOT NO. 55 SECTION OR BLOCK NO.


House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 4 No. Bathrooms 2

Garbage Disposal Unit	Yes	(✓)	No	( )	
Auto. Dishwasher	Yes	(✓)	No	( )	
Auto. Wash. Machine	Yes	(✓)	No	( )	
Site Suitable	Yes	(✓)	No	( )	

Lot Area 19,000 sqft

Character & Porosity of Soil Red Clay
Percolation Rate 30 min/inch
Topography 2-6%
Depth to Water Table 10'+
Rock or other impervious formations none



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 1000 Linear Ft. 333
Depth of Stone in Lines 16'
Water Supply: Individual ( )
Public (✓)

Installed by Hoke Septic Tank Co.

IMPROVEMENTS PERMIT BY J.C. Moore

COMMENTS:

CERTIFICATE OF COMPLETION BY Andrew E. Causey DATE 12/27/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold