IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR K & H Const. Co. DATE 11-7-73 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION East Broad St. Rt on Florence Dr. - 1st House on Rt past Montgomery Dr.


SUBDIVISION NAME Mitchell-Aire LOT NO. 60 SECTION OR BLOCK NO. _____ S. R. No. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	sandy
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	sandy
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slight slope to rear
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	n/a
			Rock or other impervious formations	

Lot Area _____



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 667½ Linear Ft. 255
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Lackey Bros
Stony Point, NC.

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Todd DATE 11-7-73

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold