IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ken Cole DATE 4-19-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION E. Broad to Michelaige, turn rt., on Montgomery Dr, and left on Schafer S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 33 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	(✓)	No	( )
Auto. Dishwasher	Yes	(✓)	No	( )
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Lot Area ½ acre

Character & Porosity of Soil Red clay
Percolation Rate none taken
Topography slope to rear and right front
Depth to Water Table _____
Rock or other impervious formations none



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Lackey Bros.

IMPROVEMENTS PERMIT BY Glenn Fox + Andrew Causey

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew Causey DATE 4-19-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold