IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System G. S. Chapter 130-Article 13C)

OWNER OR ~~(CONTRACTOR)~~ Roby Houston DATE 11-5-73 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION EAST Broad St. EXT. - TR ON Street before Greenbrier Rd. 2nd House on LEFT from END of Street S. R. No. _____


SUBDIVISION NAME Broad View - LOT NO 89-92 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	sandy
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	fast
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope To front
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	
			Rock or other impervious formations	

Lot Area ½ ACRE 19,800 ±



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 5
Sq. Ft. 675 Linear Ft. 270
Depth of Stone in Lines _____

Water Supply: Individual ( )
Public (✓)

Installed by Lackey Bros.
Stony Point, N.C.

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Fox Jr. DATE 11-5-73

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold