IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Larry Thomas DATE 9-18-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION E. Broad Ext. to Hollingwood Rd on Rt, go to Rd #2417 - on left T. L. - home on RT

S. R. No. _____


SUBDIVISION NAME Home #303 LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____ Existing house having addition

No. Bedrooms 4 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area _____

Character & Porosity of Soil Red Clay Loam
Percolation Rate none
Topography Slope to front of home
Depth to Water Table none
Rock or other impervious formations none observed



Plot of System

Hollingwood Rd

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 270
Depth of Stone in Lines 18"
Water Supply: Individual (✓)
Public ( )

Installed by Harlan Looky

IMPROVEMENTS PERMIT BY _____

COMMENTS: Existing septic tank system under proposed new addition Min. of 20' from well. 10" stone under grade board - 14" stone under pipe. Well casing over septic tank lid used.

CERTIFICATE OF COMPLETION BY Andrew E. Casey DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold