IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ben Daniels DATE 6/15/78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION E. Broad St. ext., TR on Greenbriar, TR on Randleigh Rd., house on right S. R. No. _____


SUBDIVISION NAME Broadview LOT NO. 192 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	sandy loam
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-10%
Site Suitable	Yes ( )	No ( )	Depth to Water Table	4'
			Rock or other impervious formations	None observed

Lot Area _____



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 400 Linear Ft. 300
Depth of Stone in Lines 16"

Water Supply: Individual ( )
Public (✓)

Installed by Sonny Sloan (Ben Daniels)

IMPROVEMENTS PERMIT BY _____

COMMENTS: All Distribution boxes must be set in concrete

CERTIFICATE OF COMPLETION BY Darby B. Gridley DATE 6/15/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold