DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

4 754832714

OWNER: MURIEL TURNER APPLICANT: ___
ADDRESS: CORRY ST AT END APPLICATION DATE: ___ DATE EVALUATED: ___
PROPOSED FACILITY: DW 3BR PROPOSED DESIGN FLOW (.1949): ___ PROPERTY SIZE: ___
LOCATION OF SITE: ___ PROPERTY RECORDED: ___
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFIL CLASS & LTAF
1	10% L	0-3"	scl, wk, gr	fr, ns, np, rvp		>48"			PS .3
		3-48"	c, med, sbk	fi/fr, ss, p, rvp					
2	10% L	0-3"	scl, wk, gr	fr, ns, np, rvp		>48"			PS .3
		3-48"	c, med, sbk	fi/fr, ss, p, rvp					
3	7% L	0-3	SL, wk, gr	fr, ns, np, rvp		≤ 3"			US
		3-48"	crom. 2						
4	7% L	0-8"	SL, wk, gr	fr, ns, np, rvp		≤ 8"			US
		8-48"	crom. 2						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	.3	.3
System Type(s)	YES	YES
Site LTAR	GRAVITY PANEL	LPP PANEL

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: L. COOK
OTHER(S) PRESENT: ___