DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: Wake

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: James Corry APPLICANT: Same
ADDRESS: Corry Lane APPLICATION DATE: ___ DATE EVALUATED: 3/16
PROPOSED FACILITY: ___ PROPOSED DESIGN FLOW (.1949): ___ PROPERTY SIZE: ___
LOCATION OF SITE: ___ PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	8% Linear	0-6	SL gr	Fr					PS .35
		6-10	scl	fr					
		10-24	cl	fi					
		24-46	cl/sap	fi					
		46-49	sap						
2	7% Linear	0-2	SL	Fr					PS .30
		2-25	cl	fi					
		25-42	cl/sap	fi					
		42	sap						
3	6% Repair	0-4	scl	Fr	18" PRV				
		4-18	cl	fi					
		18-24	cl	fi					
		24-49	cl/sap	fi					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Conv. Conv.	Conv. Conv.
Site LTAR	.3	.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: [illegible]
OTHER(S) PRESENT: ___