PRESSURE MANIFOLD DESIGN SPECS.

Part of Permit for Iredell County Animal Shelter

1/2" Tab equipped with 2' X 1/2" test pipe that can be disconnected and stored in manifold box.

6 - 1/2" Taps.

TOP VIEW

2" PVC, Schedule 40 (from pump tank)

lean out

12" 12" 12" 12"

3" sch 40 line

6 deliver pipe to drainlines.

2" Gate Valve

It will take 50 gal./min. to properly dose pressure manifold.

Schedule 80 PVC

Weatherproof removeable Lid.

SIDE VIEW

6" 6" 6" 5" 6"

Support Blocks

262000