IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Two's Company DATE 6-1-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION East Broad St Ext. TR on Agusta Drive


S. R. No. _____

SUBDIVISION NAME Shannon Acres LOT NO. 19 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 3½

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	Cecil Fine Sandy loam
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	60 to 100 min/inch
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 to 4%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+
Lot Area 1 acre			Rock or other impervious formations	none



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 1125 Linear Ft. 375
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Eddie Yountz + Son

IMPROVEMENTS PERMIT BY P. C. Moore

COMMENTS: landscape + run Gutters so water will not stand over Tank or lines.

CERTIFICATE OF COMPLETION BY P. C. Moore DATE 6-1-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold