IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR N.C. James DATE 4-17-80 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64E before Bowling Alley on R

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home ( ) Business (✓) Other Truck Terminal 2 Full Time Employees

~~No. Bedrooms~~ No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes ( ) No (✓)
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Cecil clay & Sandy Parent Mat.
Percolation Rate 60 to 80 min/inch
Topography 2 to 6%
Depth to Water Table 10'+
Rock or other impervious formations None

Lot Area acreage



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by Robert Hoke

IMPROVEMENTS PERMIT BY R. C. Moore

COMMENTS: No parking over tank or lines should be sowed back in good grass cover

CERTIFICATE OF COMPLETION BY R. C. Moore DATE 4-17-80

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold