IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR K+H Const. DATE 4-6-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION East Broad st. TL after 4th Creek 1st Rt TR 300' on right

SUBDIVISION NAME East Brook LOT NO. 9 SECTION OR BLOCK NO. _____ S. R. No. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 100X160

Character & Porosity of Soil Cecil Fine Sandy clay
Percolation Rate 60 min / inch
Topography 2 to 4% Slope
Depth to Water Table 10'+
Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by Paul Frye

ditch
9'X 100'
3 lines

IMPROVEMENTS PERMIT BY D. C. Moore

COMMENTS: landscape + Pipe Gutters so excess surface water is not discharge into area of Septic Tank System.

CERTIFICATE OF COMPLETION BY D. C. Moore DATE 4-6-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold