IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ray Spengler DATE 9-6-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION East Broad Ext. Cross 4th creek 1/4 mi on left. S. R. No. _____


SUBDIVISION NAME Eastbrook LOT NO. 5 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	LSB2	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	mod	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 to 6%	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10' +	
			Rock or other impervious formations	none	

Lot Area ½ acre +



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 810 Linear Ft. 270
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by JC's Back Hoe service

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 9-6-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold