IREDELL COUNTY HEALTH DEPARTMENT

City

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR THOMAS G. PARDUE DATE 7-20-84 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION EAST BROOK DEV. - 2540 Heritage Circle.

SUBDIVISION NAME EAST BROOK LOT NO. 29 S. R. No. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 3.5

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 150' x 190'

Character & Porosity of Soil clay + some saprolite
Percolation Rate 3 gal/sq. ft.
Topography 2 - 12%
Depth to Water Table 10'+
Rock or other impervious formations some leapy formations on upper sided formations

✓ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1250 GAL. TANK ~~800 GAL. PUMP~~ Gals.
Nitrification Field: TANK
No. of Lines 9
Sq. Ft. 1350 Linear Ft. 450
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by Donald Lackey

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: Box set 35'+ from center of street.

CERTIFICATE OF COMPLETION BY Steve Brewer

EXISTING SYSTEM CHECKED BY: _____ DATE 7-20-84.

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS. DATE _____

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold