## IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Fred Clarke DATE 5-10-79 PERMIT NO.

PHONE: Business Home

LOCATION East Broad at corner of Florence Rd

S. R. No.


SUBDIVISION NAME LOT NO. SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other Repair

No. Bedrooms 3 No. Bathrooms 2

| | | | | | |
|---|---|---|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No (✓) | Character & Porosity of Soil | Fine Sandy cecil clay | |
| Auto. Dishwasher | Yes (✓) | No ( ) | Percolation Rate | 60 min/inch | |
| Auto. Wash. Machine | Yes (✓) | No ( ) | Topography | 2 to 4% | |
| Site Suitable | Yes (✓) | No ( ) | Depth to Water Table | 10'+ | |
| | | | Rock or other impervious formations | none | |

Lot Area 1/2 acre




Plot of System

Size of Tank Existing Gals.
Nitrification Field:
No. of Lines 1
Sq. Ft. 375 Linear Ft. 125
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by Eddie Yountz

IMPROVEMENTS PERMIT BY L. C. Moore

COMMENTS: Landscape & Pipe Gutter so Surface water does not stand over Tank or lines

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 5-10-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold