IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ray Warren DATE 11-19-75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION E. Broad St. Tr to Eastrock - Heritage Park

_____ S. R. No. _____

SUBDIVISION NAME Eastbrook LOT NO. 48 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2 1/2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 1/2 Acre +


Character & Porosity of Soil Red Clay

Percolation Rate _____

Topography Slopes to Creek

Depth to Water Table 36+

Rock or other impervious formations None



Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 5

Sq. Ft. 750 Linear Ft. 300

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public (✓)

Installed by Jerry Sigmon

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Foster DATE 11/19/75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold