35550

10674

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John K Koehler DATE 4-24-90 PERMIT NO. 55250.25

PHONE: Business _____ Home _____

LOCATION Eastwood Dr. S. R. No. _____

SUBDIVISION NAME Broadwood Acres LOT NO. 25 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit	Yes (✓)	No ( )
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 50,312.7 SF

Character & Porosity of Soil Clayey

Percolation Rate 4

Topography 2 to 6% 10 F

Depth to Water Table _____


Rock or other impervious formations Rock 36 to 42"

_____ Basement with Plumbing ✓ Basement without Plumbing _____ No Basement

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 200 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)



Installed by Eddie Yount & Sons

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY F.C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY F. C. Moore DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold