IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Mike Griffin DATE 12-27-83 PERMIT NO.

PHONE: Business Home

LOCATION Nelly Green Rd on Finns Creek Dr. thru T.L. on 1st street, House on right at cul-de-sac. (across street) S.R. No.


SUBDIVISION NAME Nelly Green LOT NO. 7 SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2 1/2

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area ≈ 1 Acre

Character & Porosity of Soil Class IV - A clay
Percolation Rate 0.4 gal/ft²/day
Topography 2 to 6% slope
Depth to Water Table 10'+
Rock or other impervious formations none



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 1350 Linear Ft. 450
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by Wes Lytton

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY J.C. Moore

COMMENTS: Nitrification field kept shallow (≈ 1ft cover). Landscape to prevent water from standing on Sit. system. Divert gutter downspout off system.

CERTIFICATE OF COMPLETION BY Tony A Pierce

EXISTING SYSTEM CHECKED BY: DATE 12-27-83

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold