IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR EAGLE HOMEBUILDERS DATE 8-4-83 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION East Broad St., T.L. on East Bedell Drive, then T.R. on Fines Creek Drive - 1/4 mi. on left S. R. No. _____

SUBDIVISION NAME NEELY GREEN LOT NO. 15 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil clay/fine sandy clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate 60 min/in.
Auto. Wash. Machine	Yes (✓)	No ( )	Topography 2-6%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table 10'+
			Rock or other impervious formations none observed.

Lot Area 3/4 acre

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 1000 Linear Ft. 333
Depth of Stone in Lines 10"+

Water Supply: Individual ( )
Public ✓

Installed by Eddy Yount

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY J. C. Mears

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Sellers DATE 8-4-83

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold