IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Gerald Smith DATE 10-10-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION East Broad St. TL on East Iredell Dr. before School TR on Fines Dr. at corner of Haywood Circle S. R. No. _____

SUBDIVISION NAME Nolly Green Estates LOT NO. 22 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	✓	No		
Auto. Dishwasher	Yes	✓	No	( )	
Auto. Wash. Machine	Yes	✓	No	( )	
Site Suitable	Yes	✓	No	( )	

Character & Porosity of Soil Cecil clay loam
Percolation Rate 100 min/inch
Topography 2 to 6%
Depth to Water Table 10'+
Rock or other impervious formations None

Lot Area 1 acre



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public ✓

Installed by Eddie Yountz

IMPROVEMENTS PERMIT BY L. C. Moore

COMMENTS: landscape & pipe Gutters so surface water will not run into area of system.
System was rained in before covered.

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 10-10-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold