07274

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hunter-Brick DATE 2-5-88 PERMIT NO.

PHONE: Business Home

LOCATION East Broad St. Turn on Eastwood 200' on Rt.

S. R. No.

SUBDIVISION NAME Broadwood LOT NO. 4 SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil clayey
Percolation Rate 24
Topography rolling
Depth to Water Table 10'+
Rock or other impervious formations none

Lot Area 20,492

___ Basement with Plumbing ___ Basement without Plumbing ✓ No Basement



Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by Eddie Younts Sons

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS:

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 4-5-88

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold