IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jack Borders DATE 10-12-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64E TR on Greenbrair before covenant ARP 210 N Greenbrair S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 17,000 Sq'

Character & Porosity of Soil Fine Cecil Sandy Clay
Percolation Rate 50 min/inch
Topography 2 to 4%
Depth to Water Table 10 ft
Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Eddie Yountz & Son

IMPROVEMENTS PERMIT BY D. C. Moore

COMMENTS: landscape & pipe Gutters so surface water will not run into area of System

CERTIFICATE OF COMPLETION BY D. C. Moore DATE 10-12-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold