IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Buford Rimmer DATE 7-16-82 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Neely Green Estates Lot 47

S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3
Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Cecil Clay
Percolation Rate .5 gal 55' Hay
Topography 2 to 6 %
Depth to Water Table 10'+
Rock or other impervious formations none

Lot Area 3/4 acre
✓ Basement with Plumbing ____ Basement without Plumbing ____ No Basement



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public (✓)
well used for cooling system
Installed by Lee Lackey

I understand and agree to install septic tank system as specified on this Improvements Permit.

Location of the proposed REBUILT DECK addition does not appear to impact the existing on-site septic system.**NOTE: KEEP MIN 5' FROM SYSTEM
R. Steve Hedrick REHS
Date: JANUARY 28, 2013
ICHD-Environmental Health Division

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: Landscape so surface water will not stand over Tank or lines

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 7-16-82
EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold