IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Custom Kitchens DATE 11-2-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Fines Creek Drive

S. R. No. _____


SUBDIVISION NAME Nelly Green Estates LOT NO. 36 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	Cecil Sandy Clay loam
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	60 min/inch
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 to 6% Slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+
			Rock or other impervious formations	none

Lot Area 1 acre



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by J. R. Bowles

IMPROVEMENTS PERMIT BY L. C. Moore

COMMENTS: landscape & divert surface water around system. Pipe gutters away also.

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 11-2-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold