# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR P.S WEST CONST. CO. Sherrill-Parks Kennell DATE 12-13-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Lt E. TL on Rd #2158 Go Approx 1 mile - Blue on Left

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other KENNELL

No. Bedrooms 4 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No ( )

Auto. Dishwasher Yes ( ) No ( )

Auto. Wash. Machine Yes ( ) No ( )

Site Suitable Yes ( ) No ( )

Lot Area _____


Character & Porosity of Soil LFC 2

Percolation Rate 2 mpi

Topography 2-6% Slope

Depth to Water Table 10"

Rock or other impervious formations Some Noted




Plot of System

Size of Tank 1500 Baffle Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 16"

Water Supply: Individual (✓)

Public ( )

Installed by Harold Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 12/13/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold