# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jack Borders Builders DATE 5/30/79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64E., T.R. on Greenbrier Rd, T.L. on 2449, 200' on Rt

S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

| | | | | | |
|---|---|---|---|---|---|
| Garbage Disposal Unit | Yes (✓) | No ( ) | Character & Porosity of Soil | Cecil Clay loam |
| Auto. Dishwasher | Yes (✓) | No ( ) | Percolation Rate | 60 min/inch |
| Auto. Wash. Machine | Yes (✓) | No ( ) | Topography | 4% slope |
| Site Suitable | Yes (✓) | No ( ) | Depth to Water Table | 10'+ |
| | | | Rock or other impervious formations | none |

Lot Area ½ acre




Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 750 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by Eddie Yountz

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew E. Causey DATE 7/3/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold