HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Russell Beck OWNER: AGENT: PHONE: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: ____
PROPOSED FACILITY: ____
PROPERTY SIZE: ____
LOCATION OF SITE: ____
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ____ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	4% Linear	0 to 10	L	GR		1942 WETNES CONDITION	N/A
		10 to 48	C	SBK	1:1	1943/.1956 SAPROLITE	N/A
						1944 RESTRICTIVE HORIZON	N/A
						1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.24
2	4% Linear	0 to 10	L	GR		1942 WETNES CONDITION	N/A
		10 to 24	C	SBK	1:1	1943/.1956 SAPROLITE	N/A
		24 to 48	C	ABK	1:1	1944 RESTRICTIVE HORIZON	N/A
						1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.13
3						1942 WETNESS CONDITION	
						1943/.1956 SAPROLITE	
						1944 RESTRICTIVE HORIZON	
						1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
4						1942 WETNESS CONDITION	
						1943/.1956 SAPROLITE	
						1944 RESTRICTIVE HORIZON	
						1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
5						1942 WETNESS CONDITION	
						1943/.1956 SAPROLITE	
						1944 RESTRICTIVE HORIZON	
						1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (.1945) ____ SITE CLASSIFICATION (.1948): ____ SITE LONG-TERM ACCEPTANCE RATE: .35
OTHER FACTORS(.1945) ____ SYSTEM TYPE Conv. Gravity
EVALUATED BY: D.C. Moore OTHER(S) PRESENT: Russell Beck
COMMENTS: ____

DRAFT