DENR/DEH

ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #: 4755898615
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Lori Gandy
ADDRESS: 350 Mocksville Hwy
PROPOSED FACILITY: SFD
LOCATION OF SITE: 40 E to 64 E 1/2 on 64
WATER SUPPLY: (Private) • Public • Well • Spring • Other N/A
EVALUATION METHOD: (Auger Boring) • Pit • Cut

APPLICATION DATE 2/20/14
DATE EVALUATED: 2/26/14
PROPOSED DESIGN FLOW (.1949): 360
PROPERTY SIZE: .59
PROPERTY RECORDED: Yes
TYPE OF WASTEWATER: (Sewage) • Industrial Process • Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 8%	0-12	manip	—	PS	PS	36-62	N/A	PS .3
		12-28	C fi	SBk SE					
		28-36	BC fi/N	WABk SE					
		36-72	Sa(l) fi	mass N/A					
2	L 6%	0-20	manip	—	PS	PS	N/A	N/A	PS .3
		20-40	C f.	SBk SE					
		40-62	BC fi/N	WABk SE					
3									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
ilable Space (.1945)	PS	—
em Type(s)	25%	—
L TAR	.3	—

MENTS:

OTHER FACTORS (.1946): PS
SITE CLASSIFICATION (.1948): PS

EVALUATED BY: H. Snow
OTHER(S) PRESENT: