## IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Mike Lassiter DATE 4-11-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Augusta Drive

S. R. No. _____


SUBDIVISION NAME Shannon Acres LOT NO. 59 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 5 No. Bathrooms 4

| | | | | | |
|---|---|---|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No (✓) | Character & Porosity of Soil | Cecil Clay Loam |
| Auto. Dishwasher | Yes (✓) | No ( ) | Percolation Rate | 80 min/inch |
| Auto. Wash. Machine | Yes (✓) | No ( ) | Topography | 2 to 6 % |
| Site Suitable | Yes (✓) | No ( ) | Depth to Water Table | 10'+ |
| | | | Rock or other impervious formations | None |

Lot Area 170 X 250




Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1200 Linear Ft. 400
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by Hoke Septic Tank Co.

IMPROVEMENTS PERMIT BY Glenn Fox

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 4-11-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold