IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Robert Courtney House Boan Bldg Co. DATE 2-6-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Glen Eagles Rd


S. R. No. _____

SUBDIVISION NAME Shannon Acres LOT NO. 11 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 3½

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	Red Clay	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	Very Good	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slopes to Rear	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10+	
Lot Area Approx. 36,000			Rock or other impervious formations	None	



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 500 Linear Ft. 300
Depth of Stone in Lines 14"

Water Supply: Individual ( )
Public (✓)

Installed by Hicks Septic Tank Serv.

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Todd DATE 2/6/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold