IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Delbert Dicken DATE 8-18-75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64 E. Brick House Behind 4th Lane on Left past Gaither Garage - S. R. No. 64E


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No ( )	Character & Porosity of Soil	Red Clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	5 min
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slopes to East
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	5 ft
			Rock or other impervious formations	None

Lot Area 20,000



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 700 Linear Ft. 281-
Depth of Stone in Lines 18-

Water Supply: Individual ( )
Public (✓)

Installed by Delbert Dicken

IMPROVEMENTS PERMIT BY _____

COMMENTS _____

CERTIFICATE OF COMPLETION BY _____ DATE 8/18/75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold