IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ronnie Bass DATE 8/24/77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21N., T.R. on Rd #2171, cross I-77, Mobile home on left past Rd #2172 S. R. No. 2171

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


J. D. Hayes Property

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	CfBa	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	mod	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-6%	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	wk	
			Rock or other impervious formations	none observed	

Lot Area Acrage



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by Donald Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew E. Causey DATE 8/24/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold