DENR/DEH

ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #: 9756 es 3415
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Robert Thompson
ADDRESS: 127 Foxfire Ct
PROPOSED FACILITY: SFD
LOCATION OF SITE: Danbury Forest
WATER SUPPLY: • Private • Public • Well • Spring • Other
EVALUATION METHOD: • Auger Boring • Pit • Cut

APPLICATION DATE 06-30-14
DATE EVALUATED: 07-30-14
PROPERTY SIZE: .8ac
PROPERTY RECORDED: Yes
TYPE OF WASTEWATER: • Sewage • Industrial Process • Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 12%	0-30	C fi	SBK SE	PS	PS	W/A	W/A	PS .3
		30-48	Bc fi/K	WABK SE					
2	L 13%	0-30	C fi	SBK SE	PS	PS	W/A	W/A	PS .3
		30-48	Bc fi/K	WABK SE					
3	L 9%	0-8	manip	—	PS	PS	W/A	W/A	PS .3
		8-34	C fi	SBK SE					
		34-48	Bc fi/K	WABK SE					
4	L 10%	0-6	manip	—	PS	PS	W/A	W/A	PS .3
		6-33	C fi	SBK SE					
		33-48	Bc fi/K	WABK SE					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	25%	50%
Site LTAR	.3	.3

OTHER FACTORS (.1946): PS
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: H. Snow
OTHER(S) PRESENT:

COMMENTS: