IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Fortis Corp DATE 10-26-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Danbury Forest Lot 37

S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Cecil Clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	100 min/inch
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 to 6% slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+
			Rock or other impervious formations	none

Lot Area ½ acre



Plot of System

Size of Tank 1000 Gals.
Nitrification Field: 2
No. of Lines _____
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Pfass & Sale

IMPROVEMENTS PERMIT BY R. C. Moore

COMMENTS: landscape & pipe Gutters to prevent surface water from standing over Tank or lines

CERTIFICATE OF COMPLETION BY R. C. Moore DATE 10-26-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold