IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Fortis Corp DATE 5-4-79 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION Jane Sowers Rd

SUBDIVISION NAME Danbury Forest LOT NO. 38 SECTION OR BLOCK NO. _____ S. R. No. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	cecil Clay	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	80	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 to 6%	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+	
Lot Area ½ acre +			Rock or other impervious formations	none	



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 10

Water Supply: Individual ( )

Public (✓)

Installed by Pfass + Sale

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: landscape so water will not stand over tank or lines.

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 5-4-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold