IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Wayne Queen DATE 7-25-74 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION Hwy 21N. to White Sales - T.R. + go across I-77 to Rd # 2173 on left, go to green house on left. Trailer behind S.B. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area _____

Character & Porosity of Soil Red clay loam
Percolation Rate 20 min
Topography Slight slope
Depth to Water Table —
Rock or other impervious formations none encountered



Plot of System

Size of Tank 1,000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10
Water Supply: Individual (✓)
Public ( )

Installed by Larry Shepard

IMPROVEMENTS PERMIT BY _____

COMMENTS: water from well at house
Improvements permit made to John Wayne
Tank from Statesville Concrete - questionable construction

CERTIFICATE OF COMPLETION BY Andrew E. Causey DATE 7-25-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold